

PLYMPTON BOARD OF HEALTH	OPEN MEETING NOTES	May 8, 2018	Next Meeting 5/8/18 @ 5:00 PM
Present/Absent		Present/Absent	Place: BOH Office, Town House
Chair: Arthur Morin, Jr. P			
Treasurer: Harry Weikel, Jr. P	Health Agent: Robert Tinkham P		
Clerk: Brad Cronin A	Administrative Assistant: Cathleen Ferguson P		
TOPIC/AGENDA---NAME & ADDRESS			
ASSESSOR'S MAP - BLOCK - LOT	PROBLEM/DISCUSSION		FINDINGS/RECOMMENDATIONS
Call to Order 5:02 p.m.	Minutes of April 24, 2018		Approved.
OLD BUSINESS			
4 Mayflower Road (M17-B5-L6)	Update on trash problem		Realtor reports closing scheduled for May 30th
44 Prospect Road (M20-B1-L3)	Update		Still waiting for owner to submit water test.
61 Crescent Street (M7-B4-L2)			Being installed.
0 Center Street (M11-B2-L14)	New Septic System		Plan approved; to be installed.
0 Maple Street (M7-B2-L7)	New Septic System		Plan approved; to be installed.
31 Main Street (M4-B3-L14)	Repair of septic system		Being installed.
200 Center Street (M11-B2-L13)	New Septic System		Being installed.
0 West Street (M15-B2-L4)	Installation of Septic System		Plan approved; to be installed.
133 County Road (M5-B1-L4)	Repair of Septic System		Plan approved; to be installed.

MINUTES OF THE MEETING	PAGE TWO	5/8/2018
8 Churchill Road (M18-B4-L15)	Application for Perc Test	Motion made to approve Septic Permit #1212.
		Motion made to approve variance to allow a
		SAS 61 feet from wetlands instead of 100; variance to allow a
		finish slope of 3:1 instead of 10:1; variance to allow a SAS
		110 feet, 129 feet and 163 feet from existing wells instead of
		200 feet; variance to allow a 5 foot remove and replace
		instead of 10 feet. All motions voted 2-0 to approve.
62 County Road (M4-B1-L4)	Repair of Septic System	Being installed.
28 Oak Street (M2-B1-L2)	New Septic System	Being installed.
76 Parsonage Road (M21-B2-L4)	Request for Perc	Passed; waiting for septic plan.
104 Upland Road (M18-B4-L8)	Request for Perc	Plan sent to reviewer.
0 Cedar Street (M15-B1-L9)	New Septic System	Voted 2-0 to approve Septic Plan # 1213.
0 West Street (M15-B2-L4)	Application for Building Permit	Waiting for well to be installed in order to sign off on
		building permit.
NEW BUSINESS		
40 Upland Road (M13-B1-L9)	Application for Perc Test	Perc Test scheduled for 5/11.
89 Ring Road (M8-B2-L11)	Replace D-Box	Inspected 5/8. COC signed.
0 Winnetuxet Road (M21-B1-L14A)	New Septic System	Voted 2-0 to approve Septic Plan #1214.

MINUTES OF THE MEETING	PAGE THREE	5/8/2018
OTHER		
Mail		Reviewed.
Bills/Warrants		Signed.
Administrative Updates	Title 5 Supplemental Regulations	Will discuss with full board.
89 Palmer Road	Owner reports house is sold and all trailers have been removed.	
Adjournment		Motion made & voted 2-0 to adjourn. Adjourned at 5:45 p.m.